



Concentrated Sources of Potential Contamination
[livestock or poultry yards, cemeteries, pesticide facilities, etc]



Property Line

Minimum Horizontal Distance 150 feet


Minimum Horizontal Distance of 100 feet
Except as noted in Rules

Public Water Supply wells may require 150 foot Sanitary Easement

Minimum Horizontal Distance of 50 feet



Minimum Distance
5 feet for Exempt Well
(pressure cemented)
Minimum Distance 50
feet for Non-Exempt
Well



Lower Trinity Groundwater Conservation District

Well Location

Note: Minimum distance from the well (exempt) to the property line if not pressure cemented = 5 feet;
if pressure cemented = 100 feet.